



**Sidney B. Bowne
& Son, LLP**
235 East Jericho Turnpike
PO Box 109
Mineola, NY 11501-0109
Phone: 516-746-2350
Fax: 516-747-1396
www.bownegroup.com

July 5, 2017

Board of Commissioners
Massapequa Water District
84 Grand Avenue
Massapequa, NY 11758

Re: Location of the Iron Removal Building, NEWF

Gentlemen:

As requested by the Board of Commissioners, we have again reviewed the Northeast Well site for alternate locations for the iron removal plant building. The middle of the site, while currently open, has been reserved for future treatment facilities that may be needed to remove contaminants such as those that affected other water districts. These contaminants could impact the wells at both ends of the site; hence the central location on the property.

In addition, the middle of the site has underground piping and electric duct banks running between the well houses.

For the reasons above, we recommend leaving the iron removal building where is shown on the plans.

Sincerely,

A handwritten signature in blue ink that reads 'John M. Waltz'. The signature is fluid and cursive, with a large initial 'J' and 'W'.

John M. Waltz, P.E.
Associate Partner

cc: Stan Carey, Superintendent
Joseph Fusillo,

T:\Water\Massapequa\66631-IronRemovalFacilityNEWF_General\Doc\Massapequa WD\Iron Building Site Location 7July2017.docx