

NASSAU COUNTY DEPT. OF HEALTH

SAMPLING SITE LOCATION & MONITORING RESULTS

SYSTEM NAME: Massapequa Water District

TELEPHONE NO.: 516-798-5266

CONTACT PERSON: Stan Carey

LEAD & COPPER TAP RESULTS

Number of lead/copper tap samples required.	<u>30</u>
Number of lead/copper tap samples submitted.	<u>30</u>
Lead level 90 th percentile	<u>0</u> mg/l.
Copper level 90 th percentile	<u>0.17</u> mg/l.
Sample collection date range	<u>6/23/2020</u> to <u>7/24/2020</u>

WATER QUALITY PARAMETER RESULTS

Number of water quality parameter tap samples required.	<u>30</u>
Number of water quality parameter tap samples submitted.	<u>30</u>
Number of water quality parameter entry point samples required.	<u>30</u>
Number of water quality parameter entry point samples submitted	<u>30</u>

CERTIFICATION OF COLLECTION METHODS:

I certify that:

Each first draw sample for lead and copper is one liter in volume and has stood motionless in the plumbing system of each sampling site for at least six hours.

Each first draw sample collected from a single-family residence has been collected from the cold water kitchen tap or bathroom sink tap.

Each first draw sample collected from a non-residential building has been collected at an interior tap from which water is typically drawn for consumption.

Each first drawn sample collected during an annual or triennial monitoring period has been collected in the months June, July, August, or September.

Each sampling site does not include faucets that have point of use or point of entry treatment devices designed to remove inorganic/contaminants.

Each resident who volunteered to collect tap water samples from his/her home has been properly instructed by Massapequa Water District (insert water system's name) in the proper methods for collecting lead and copper samples. I do not challenge the accuracy of these sampling results. Enclosed is a copy of the material distributed to residents explaining the proper collection methods, and a list of the residents who performed sampling.